009316r

4 wells

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91880
Permit No.
Basin 212

NOTICE OF INTENT NO. 25809

1. OWNER G.A. Bagyczk
MAILING ADDRESS 145 S. State College Blvd
Brea CA. 92822

ADDRESS AT WELL LOCATION 3805 E. Flamingo Rd.
Las Vegas, NV 89121

2. LOCATION NW ¼ NE ¼ Sec. 19 T. 21 N/S R. 62 E County

PERMIT NO. Issued by Water Resources | Parcel No. 161-19-501-001 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Type II Fill		0.0	2.0	2.0
Sandy Clay		2.0	8.0	6.0
Gravelly clay		8.0	12.0	4.0
Silty sand w/ Gravel		12.0	20.0	8.0
Sandy Gravel		20.0	35.0	15.0

DCNR/DWR
RECEIVED
DEC 8 1 2003
LAS VEGAS OFFICE

Date started 11/25, 2003
Date completed 12/15, 2003

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 35.0 Feet Depth Cased 35.0 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11 1/2 Inches		0.0 Feet	35.0 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.250		sch 40 PVC	10.0	0.0

Perforations:
Type perforation Machine slotted
Size perforation .020
From 35.0 feet to 10.0 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 1'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 35 feet to 8.0 feet

9. WATER LEVEL
Static water level 14' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eagle Drilling Services (Contractor)
Address 7150 Placid St (Contractor)
Las Vegas, NV 89119
Nevada contractor's license number issued by the State Contractor's Board 57266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2202
Signed (By driller performing actual drilling on site or contractor)
Date 12/24/03

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627