WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.34

OFFICE USE ONLY
Log No. 91925
Permit No.
Basin 106

NOTICE OF INTENT NO. 45505

1. OWNER DAVID NEFF
MAILING ADDRESS HC60-BOX 536
RUBY VALLY, NV 89833

ADDRESS AT WELL LOCATION

2. LOCATION SE 1/4 SE 1/4 Sec. 15 T 32 N/S R 60 E ELKO County
PERMIT NO. (Issued by Water Resources) TRACK (Parcel No.) RUBY VALLEY (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
LOAM		0	7	7
SANDY CLAY		7	49	42
CLAY		49	55	6
HARD CALICHI CLAY		55	68	13
SOFT SAND STONE	X	68	100	32

RECEIVED
03 AUG 14 PM 11 11
STATE ENGINEERS OFFICE

Date started 6/15/2003, 19__
Date completed 6/17/2003, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	85		3.5

8. WELL CONSTRUCTION
Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	100	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+1	100

Perforations:
Type perforation MILL SLOT
Size perforation 3/16 X 3
From 79 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From 50 feet to 100 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name SHAREL FERTING SR., DBA FERTING DRILLING CO. (Contractor)
Address PO BOX 525 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 0031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed (By driller performing actual drilling on-site or contractor)
Date 7/15/2003

USE ADDITIONAL SHEETS IF NECESSARY