WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91926
Permit No.
Basin 093

NOTICE OF INTENT NO. 50541

1. OWNER CALVIN MONCRIETF
MAILING ADDRESS 8945 ARTESIAN WAY
RENO, NV. 89506

ADDRESS AT WELL LOCATION 1225 ALUM ROCK RD
RENO, NV.

2. LOCATION NW ¼ SW ¼ Sec. 11 T 22 N/S R 19 E WASHOE County

PERMIT NO. (Issued by Water Resources) | 079-500-36 (Parcel No.) | Red ROCK ESTATES/ ANTELOPE VALLEY (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[X] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND / LIGHT BROWN		0	180	180 ft
SAND/ clay/ DARK Brown	189	180	189	9 ft
Rock / light Gray		189	208	19 ft
ROCK/ light to Dark gray		208	250	42 ft

Date started APRIL 26, 2003
Date completed JULY 28, 2003

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [X] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
08-10-03	20 +	2 FEET	4 Hours

8. WELL CONSTRUCTION
Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
9 Inches		50 Feet	250 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5.563	2.86	SDR 21.¼	1+	250

Perforations:
Type perforation FACTORY SCREEN
Size perforation 3 x .065
From 205 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 55 Feet
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 55 feet to 250 feet

9. WATER LEVEL
Static water level 185 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WILLIAM GEORGE MOSEGAARD (Contractor)
Address 7900 N Virginia St, #21 (Contractor)
RENO, NV. 89506

Nevada contractor's license number issued by the State Contractor's Board 53579

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2211

Signed William George Mosegaard
By driller performing actual drilling on site or contractor
Date 8-15-2003

RECEIVED 03 AUG 18 P1:12:07 STATE ENGINEER'S OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627