


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



OFFICE USE ONLY

Log No. 919.30
 Permit No. _____
 Basin 047

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 49020

1. OWNER BRYAN BASTASINI
 MAILING ADDRESS 945 JUNIPER HILL RD
RENO, NV 89509

ADDRESS AT WELL LOCATION SMITH CREEK ROAD NEAR
JIGGS, NV

2. LOCATION SE 1/4 NE 1/4 Sec. 20 T 30N
 PERMIT NO. _____
 Issued by Water Resources _____ Parcel No. 084-000-016

N/S R 57E E ELKO County
SMITH CREEK RANCHES Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOPSOIL		0	3	3
BROWN CLAY & GRAVEL		3	320	317
QUARTZ GRAVEL		320	400	80
GRANITE	360	400	560	160
	480	560		

SEALED WITH 25 BAGS OF 3/8 HOLE PLUG AND 3 BAGS OF CEMENT

8. WELL CONSTRUCTION

Depth Drilled 560 Feet Depth Cased 560 Feet

HOLE DIAMETER (BIT SIZE)

	From	To		
<u>10 5/8</u> Inches	0	560	Feet	Feet
Inches			Feet	Feet
Inches			Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>+1</u>	<u>560</u>

Perforations:

Type perforation WITH AIR PERFORATOR
 Size perforation 3/16 X 1

From	feet to		feet
	<u>380</u>		<u>400</u>
	<u>480</u>		<u>500</u>
	<u>540</u>		<u>560</u>

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 50 Cement Grout
 Placement Method: Pumped Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 560 feet

9. WATER LEVEL
 Static water level 160 feet below land surface
 Artesian flow _____ G.P.M. P.S.I.
 Water temperature C °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING, INC. Contractor
 Address P.O. BOX 850 Contractor

ELKO, NV 89803
 Nevada contractor's license number issued by the State Contractor's Board 020582

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689

Signed [Signature]
 By driller performing actual drilling on-site or contractor

Date 8/8/2003

Date started 8/4/2003, 19__
 Date completed 8/7/2003, 19__

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input checked="" type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>10</u>		<u>4</u>	

RECEIVED
 AUG 20 AM 10:58
 STATE ENGINEERS OFFICE