WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 29/932
Permit No.
Basin 212

NOTICE OF INTENT NO. 23474

1. OWNER WL HOMES LLC
MAILING ADDRESS 4435 S JONES #1
LAS VEGAS, NV 89103-3307

ADDRESS AT WELL LOCATION Desert Inn & Cabana
LAS VEGAS, NV

2. LOCATION SE ¼ SE ¼ Sec. 15 T. 21 N/S R. 62 E. CLARK County
PERMIT NO. DW1153 (Issued by Water Resources) | 161-15-801-001-002 (Parcel No.) | JOHN LAING HOMES-DESERT INN (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE De Water
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Plug 10-30' dewater wells | | | | |
| | | | | |
| Depth 30' | | | | |
| Perforate from 30 to 21' | | | | |
| Pull & drill out casings | | | | |
| Trimmed 2.8 yards of 4000 | | | | |
| Grout 9 sack into each well. | | | | |

Date started 12/3/03, 20
Date completed 12/4/03, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 30' Feet Depth Cased 30' Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 24" Inches | 0' Feet | 30' Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| | | | | |
| | | | | |
| | | | | |

Perforations: MACHINE
Type perforation
Size perforation 20' 30'
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From 0' feet to 30' feet

9. WATER LEVEL
Static water level 2' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ALLEN DRILLING INC. (Contractor)
Address 4015 WEST TOMPKINS (Contractor)
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 18917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller ABDS2161
Signed (By driller performing actual drilling on site or contractor)
Date 12/15/03

(Rev 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627