

OFFICE USE ONLY
 Log No. 91947
 Permit No. _____
 Basin 163

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25220

1. OWNER ROY & GAYLE SHELTON ADDRESS AT WELL LOCATION 1090 W NICKLE NICKEL AV. & PAPA90 ST. SANDY VALLEY NV
 MAILING ADDRESS _____
 2. LOCATION NE 1/4 NE 1/4 Sec. 35 T. 24 N. 56 E. CLARK County
 PERMIT NO. 200-35-501-007 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	3	3
CALICHE		3	6	3
CLAY		6	28	22
CALICHE		28	32	4
CLAY		32	58	26
CALICHE	W.B	58	64	6
CLAY		64	84	20
CALICHE	W.B	84	88	4
CLAY		88	102	14
CALICHE	W.B	102	114	12
CLAY		114	129	15
CALICHE	W.B	129	135	6
CLAY		135	140	5

DCNR/DWR
 RECEIVED
 DEC 31 2003
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
10 5/8 Inches From 0 Feet To 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>4.33</u>	<u>.316</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation SAW CUT
 Size perforation 8 INCH BY 6 INCH
 From 140 feet to 100 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 140 feet to 50 feet

9. WATER LEVEL
 Static water level 52 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality _____

Date started 12-19- 2003
 Date completed 12-22 2003

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name BUDGET DRILLING CO Contractor
 Address P.O. BOX 3505 Contractor
RAHRUMP NV. 89041
 Nevada contractor's license number issued by the State Contractor's Board 40020
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller. 1573
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 12-26-2003