

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25223

1. OWNER JAY + TERA CONNOR ADDRESS AT WELL LOCATION JASPER AV. + PAWNEE ST. SANDY VALLEY NV
 MAILING ADDRESS _____
 2. LOCATION NW 1/4 NE 1/4 Sec 26 T 24 N R 56 E CLARK County
 PERMIT NO. 200-26-501-017 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE Domestic Municipal/Industrial Irrigation Monitor Test Stock
 5. WELL TYPE Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY LOAM		0	5	5
CLAY		5	36	31
CALICHE		36	41	5
CLAY		41	52	11
CALICHE		52	55	3
CLAY		55	71	16
CALICHE	W.B	71	79	8
CLAY		79	92	13
CALICHE	W.B	92	98	6
CLAY		98	118	20
CALICHE	W.B	118	124	6
CLAY		124	134	10
CALICHE	W.B	134	140	6

DO NOT DRINK
 RECEIVED
 JAN 17 2004
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
10 5/8 Inches From 0 Feet To 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>7.33</u>	<u>1.316</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation SAW CUT
 Size perforation 1/2 INCH BY 6 INCH
 From 100 feet to 140 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 140 feet to 50 feet

9. WATER LEVEL
 Static water level 6.5 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name BUDGET DRILLING CO Contractor
 Address P.O. BOX 3505 PAHRUMP NV 89041 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 40020
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 1-14-2004

Date started 1-8, 2004
 Date completed 1-13, 2004

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)