

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 25757

1. OWNER Richard Sebastian ADDRESS AT WELL LOCATION 2030 W. Panorama  
 MAILING ADDRESS Amargosa Valley, Nv. 89020

2. LOCATION NE 1/4 SE 1/4 Sec. 4 T. 16 N. R. 48 E NVE County

PERMIT NO. 19-711-23 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVD  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Snd		0	2	2
shale		2	20	18
gravel w/ sand layers		20	115	95
limestone		115	124	9
Snd		124	138	14
gravel w/ sand	1st	135	150	15
limestone		150	158	8
snd w/ gravel		158	185	27
limestone		185	192	7
Snd		192	200	8
Bottom of well			200	

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)  
 From 12 1/4 Inches To 0 Feet 200 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	PVC		0	200
8	steel	.188		7

Perforations:  
 Type perforation Machined  
 Size perforation OR, .032 Screen

From 135 feet to 195 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 50'  
 Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 50 feet to 200 feet

9. WATER LEVEL  
 Static water level 125 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 12-14-03 20  
 Date completed 12-21-03 20

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Great Basin Drilling Contractor  
 Address P.O. Box 4220 Contractor  
Palrump, Nv. 89041

Nevada contractor's license number issued by the State Contractor's Board 047333  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2160

Signed Reed Hobbs  
 By driller performing actual drilling on site or contractor  
 Date 12-22-03