WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 91990
Permit No. 82805
Basin 106

NOTICE OF INTENT NO. 50900

1. OWNER Holbrooke Station LLC
MAILING ADDRESS 1501 Hwy 395 So Gardnerville, NV 89410
ADDRESS AT WELL LOCATION 1501 Hwy 395 So Gardnerville NV 89410

2. LOCATION NW ¼ NE ¼ Sec. 18 T. 10 N/S R. 22 E Douglas County
PERMIT NO. 41463 82805 (Issued by Water Resources) 1022-18001 01 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☒ Replace (No) ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/~~Industrial~~ (Quasi) ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
fill		0	30	30
Valley fill w/ a little clay		30	120	90
Valley fill with old soil horizons turned to clay		120	200	80
Volcanic Rock - Broken with few clay layers intermittent		200	360	160
fractured Volcanic Rock		360	400	40
38° 44.086 N				
119° 33.439 W 5452' elev				

Date started 6-7-03, 19
Date completed 6-28-03, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
225	240'	8 hours

8. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
15	0	400

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8		.188	+2	100
8 5/8		.188	140	200

Perforations:
Type perforation Factory slot
Size perforation
From 100 feet to 140 feet
From feet to feet
From 200 feet to 400 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 400 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Sierra Nevada Drilling & Pump LLC (Contractor)
Address 3540 Green Acres Dr (Contractor)
Carson City NV 89705
Nevada contractor's license number issued by the State Contractor's Board 52078
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1902
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 6-29-03

(Rev. 3-91) 8/7/13 changes by L.M.J. USE ADDITIONAL SHEETS IF NECESSARY (O)-627