

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 48552

1. OWNER Barbara Gilman ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1705 Bronze Hill Rd 1705 Bronze Hill Rd
Reno NV 89506 Reno NV 89506
 2. LOCATION NW 1/4 SW 1/4 Sec. 13 T. 22 S. R. 19 E. Washoe County
 PERMIT NO. 074-481-17 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MND

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	14	14
Rock		14	25	11
Sand		25	40	15
Rock		40	130	90
Clay		130	138	8
Rock		138	176	38
Clay		176	185	9
Rock & Clay		185	202	17
Rock (Fract)	X	202	240	38

8. WELL CONSTRUCTION
 Depth Drilled _____ Feet Depth Cased _____ Feet
 HOLE DIAMETER (BIT SIZE)
 From To
11 Inches 0 Feet 110 Feet
8 3/4 Inches 110 Feet 240 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>12.9</u>	<u>3/16</u>	<u>2+</u>	<u>240</u>

Perforations:
 Type perforation Saw slot
 Size perforation 3 1/8
 From 240 feet to 200 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 240 feet

9. WATER LEVEL
 Static water level 55 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature NA °F Quality NA

Date started 6/30, 2003
 Date completed 7/20, 2003

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>40+</u>	<u>180</u>	<u>8</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Olencki Drilling & Pump Contractor
 Address 15045 Red Rock Rd Contractor
Reno NV 89506
 Nevada contractor's license number 50343
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1656
 Division of Water Resources, the on-site driller
 Signed John F Olencki
 By driller performing actual drilling on site or contractor
 Date 8/6/03

RECEIVED
 03 AUG - 8 AM 11:05
 WATER RESOURCES OFFICE