WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92004
Permit No.
Basin 085

NOTICE OF INTENT NO. 39894

1. OWNER Joy Panella
MAILING ADDRESS 3300 Skyline #222, Reno, NV 89506
ADDRESS AT WELL LOCATION 250 Los Arboles, Reno, NV 89506

2. LOCATION NE ¼ NE ¼ Sec. 17 T. 21 N/S R. 21 E. Washoe County
PERMIT NO. N/A Issued by Water Resources
076-310-27 Parcel No.
Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Clay		0	115	
Altered Volcanic				
Sand & Clay		115	190	
Black Rock		190	220	
Red & Black Rock		220	270	
Black Sandstone		270	310	
Black Rock		310	375	
Green Rock		375	450	
Pink Granite		450	616	
Black Rock		616	787	
Brown Clay		787	786	
Green Rock		786	865	
Brown Sandy Clay		865	875	

Drilled 6 1/8" test hole from 616-875
Sandy clay caving in, plugged back to 680' with bentonite and plugged from 680' back to 616' with neat cement

RECEIVED
AUG - 7 AM 10:56
ENGINEERS OFFICE

Date started 8-26-03, 19
Date completed 9-23-03, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx	5	600	6 hrs

8. WELL CONSTRUCTION
Depth Drilled 875 Feet Depth Cased 616 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 1/4 Inches		0 Feet	25 Feet
9 7/8 Inches		25 Feet	616 Feet
6 1/8 Inches		616 Feet	875 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	14	.188	-1	616

Perforations:
Type perforation Mill Slot
Size perforation 1/8" x 3"
From 260 feet to 320 feet
From 440 feet to 460 feet
From 580 feet to 600 feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50+
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 616 feet

9. WATER LEVEL
Static water level 241 feet below land surface
Artesian flow none G.P.M. none P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce Miller - Miller & Sons Drilling Co. Contractor
Address PO Box 8056 Contractor
Reno, NV 89507
Nevada contractor's license number issued by the State Contractor's Board 37915
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418
Signed Bruce Miller
By driller performing actual drilling on site or contractor
Date 8-6-03

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627