

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 92007
 Permit No. _____
 Basin 141

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 49036

1. OWNER NEAL F. JONES ADDRESS AT WELL LOCATION BELMONT, NV
 MAILING ADDRESS 1324 BON REA WAY
RENO, NV 89503

2. LOCATION SE 1/4 NE 1/4 Sec. 26 T 9N N/S R 45E E NYE County
 PERMIT NO. _____ Issued by Water Resources Parcel No. 04-538-06 BELMONT TOWNSITE Subdivision Name

3. WORK PERFORMED New Well Replace Recondition Domestic Irrigation Test Cable Rotary RVC
 Deepen Abandon Other _____ Municipal/Industrial Monitor Stock Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOPSOIL		0	2	2
BOULDERS		2	6	4
GRANITE		6	60	54
GRANITE & QUARTZ	100	60	160	100
	120			

Sealed with 22 bags of 3/8 hole plug and 3 bags of cement

8. WELL CONSTRUCTION

Depth Drilled 160 Feet Depth Cased 145 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>+1</u>	<u>145</u>

Perforations:
 Type perforation MILLSLOT
 Size perforation 1/8 X 3
 From 125 feet to 145 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 145 feet

9. WATER LEVEL

Static water level 93 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature C °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING, INC Contractor
 Address P.O. BOX 850 Contractor

ELKO, NV 89803
 Nevada contractor's license number issued by the State Contractor's Board 020582

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689

Signed [Signature]
 By driller performing actual drilling on site or contractor

Date 9/30/2003

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>35</u>		<u>2</u>	