WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92014
Permit No.
Basin 137B

NOTICE OF INTENT NO. 13943

1. OWNER Round Mountain Gold Corp
MAILING ADDRESS P.O Box 480
Round Mountain Nevada 89045

ADDRESS AT WELL LOCATION Minesite South Pad

2. LOCATION NE ¼ NE ¼ Sec. 3 T. 9 N/S R. 43 E. Nye County

PERMIT NO. ____ Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☒ Other Casing Hammer

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	5	
Boulder - Granite		5	8	
granite/rhyolitic		8	208	
Alluvium				
Sands & gravel	✓	208	260	
gravel with clay	✓	260	300	
stringers				
light brown sand	✓	300	316	
Seal Info				
bentonite chips		20	214	
Neat Cement		0	20	

Date started 12-18-03, 19__
Date completed 12-23-03, 19__

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		4

8. WELL CONSTRUCTION
Depth Drilled 316 Feet Depth Cased 316 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
9 5/8 Inches	0 Feet	316 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"		Sch 40 PVC	0	316

Perforations:
Type perforation PVC slotted screen
Size perforation .020
From 216 feet to 296 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 20'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 214 feet to 316 feet

9. WATER LEVEL
Static water level 211.5 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WDC Exploration
Contractor
Address P.O. Box 141
Contractor
Zamora Calif. 95698

Nevada contractor's license number issued by the State Contractor's Board 0012852

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2244

Signed Randy Cuiver
By driller performing actual drilling on site or contractor

Date 1-10-04

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627