



Log No. 92018  
 Permit No. \_\_\_\_\_  
 Basin 106

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 50199

1. OWNER Wylie Wilson ADDRESS AT WELL LOCATION 4448 Hwy 208  
 MAILING ADDRESS Gardnerville, Nv  
 2. LOCATION NE 1/4 SW 1/4 Sec. 7 T10 N/S R. 23 E Douglas County  
 PERMIT NO. 1023-07-002-003 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Hand

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand boulders</u>		<u>0</u>	<u>6</u>	
<u>Boulders</u>		<u>6</u>	<u>96</u>	
<u>Granite pebbles</u>		<u>36</u>	<u>281</u>	
<u>Hard Granite</u>		<u>281</u>	<u>415</u>	
<u>Fractured Granite</u>		<u>415</u>	<u>450</u>	

8. WELL CONSTRUCTION  
 Depth Drilled 450 Feet Depth Cased 450 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
<u>10 5/8</u>	<u>0</u>	<u>60</u>
<u>6 3/8</u>	<u>60</u>	<u>300</u>
<u>6 1/8</u>	<u>300</u>	<u>450</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 5/8</u>	<u>13 1/6</u>	<u>3/16</u>	<u>1</u>	<u>300</u>
<u>6 1/8</u>	<u>3 00</u>	<u>3/16</u>	<u>290</u>	<u>450</u>

Perforations:  
 Type perforation Scill Sew  
 Size perforation \_\_\_\_\_  
 From 450 feet to 450 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 0-50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 300 feet

9. WATER LEVEL  
 Static water level 175 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 9-19 192003  
 Date completed 10-20 2003

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>produced about</u>	<u>30</u>	<u>6 PM</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge  
 Name Teach Drilling Inc  
 Address PO Box 577  
Silver Springs NV 89409  
 Nevada contractor's license number 0031841  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1877  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 10-20-03