WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92026
Permit No.
Basin 103

NOTICE OF INTENT NO. 49169

1. OWNER Shaunett Williamson
MAILING ADDRESS 1636 Truckee Drive
Carson City, NV 89701

ADDRESS AT WELL LOCATION 6105 Rio Vista
CarsonCity,Nevada 89701

2. LOCATION SE 1/4 NE 1/4 Sec. 2 T 14N N/S R 20E E Carson City County
PERMIT NO. Issued by Water Resources
010-503-27 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	107	107
Clay		107	155	48
D.G.	x	155	290	135
T.D. 290		290		

Date started 09/25/2003 , 19__
Date completed 10/02/2003 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15	220	1hour
30	240	1/2hour
40	260	1/2hour
60	280	1hour

8. WELL CONSTRUCTION
Depth Drilled 290 Feet Depth Cased 290 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10-5/8	Inches	0	Feet	100	Feet
8-3/4	Inches	100	Feet	290	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.9	.188	+2	290

Perforations:
Type perforation Factory Milled
Size perforation 3/32 x 3
From 250 feet to 290 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 290 feet

9. WATER LEVEL
Static water level 190 feet below land surface
Artesian flow G.P.M. P.S.I
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. Pump & Well Service
Contractor
Address P.O. Box 60130
Contractor
Reno,Nevada 89506
Nevada contractor's license number issued by the State Contractor's Board 35387-B
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2121
Signed [signature]
By driller performing actual drilling on-site or contractor
Date 10/13/2003

USE ADDITIONAL SHEETS IF NECESSARY