WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92036
Permit No.
Basin 02

NOTICE OF INTENT NO. 49185

1. OWNER M. HILL
MAILING ADDRESS 5880 PEAK AVENUE
SILVER SPRINGS, NV

ADDRESS AT WELL LOCATION 5880 PEAK AVENUE

2. LOCATION SE 1/4 SE 1/4 Sec. 2 T 17 N/S R 24 E LYON County
PERMIT NO. Issued by Water Resources
Parcel No. 017-013-11
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	
COLBBLES/CLAY		1	50	49
C GRAVEL/CLAY		50	250	200
HARD BLACK ROCK		250	350	100
FRACTURED BLACK ROCK	X	350	430	80

RECEIVED
OCT 9 AM 11:39
STATE ENGINEERS OFFICE

Date started 9/10/1903 2003, 19__
Date completed 9/13/1903 2003, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50		2 HR

8. WELL CONSTRUCTION
Depth Drilled 430 Feet Depth Cased 430 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	50	Feet
8 3/4	Inches	50	Feet	250	Feet
8	Inches	250	Feet	430	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	430

Perforations:
Type perforation MACHINE SLOT
Size perforation .080
From 410 feet to 430 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 258 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP. Contractor
Address P. O. BOX 888 Contractor
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
Signed By driller performing actual drilling on-site or contractor
Date 10/4/2003

USE ADDITIONAL SHEETS IF NECESSARY