



Log No. 92047
 Permit No. _____
 Basin. 102

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 45653

1. OWNER Bill Cherry ADDRESS AT WELL LOCATION 1590 Grouse ST.
 MAILING ADDRESS 2880 Ramsey ST. Silver Springs, NV 89429
 2. LOCATION NW 1/4 SE 1/4 Sec. 30 T. 17 N. R. 25 E. LYON County
 PERMIT NO. 17-553-07 Parcel No. RiverSide Sub #2 parcel 31 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RYC
 Air Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP Soil		0	1	1
Fine Sand To coarse				
Sand w/ clay Strata		1	8	7
Brown Clay		8	14	6
Fine To coarse Sand	X	14	62	48
Bluish Gray Fine To coarse Sand w/ clay		62	88	26
Bluish Gray coarse Sand & Clay		88	102	14
Bluish Gray Clay & coarse Sand		102	124	22
Coarse Sand & Small Gravel	X	124	160	36

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 161 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 160 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>12.92</u>	<u>.188</u>	<u>71</u>	<u>19</u>
<u>6 3/8</u>	<u>apt</u>	<u>.280</u>	<u>19</u>	<u>20</u>
<u>6 3/8</u>	<u>WV 4.06</u>	<u>SDR21 .316</u>	<u>20</u>	<u>160</u>

Perforations:
 Type perforation Sewed
 Size perforation 1.035 x 2" x 5 Rows
 From 140 feet to 160 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
10' 30% Bentonite Grout
 Gravel Packed: Yes No
 From 50 feet to 160 feet

9. WATER LEVEL
 Static water level 38.6 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Edmund Miller Drilling Contractor
 Address P.O. Box 92 Contractor
Smith, NV 89430
 Nevada contractor's license number 32166-A
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 634
 Division of Water Resources, the on-site driller.
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 10-16-03

Date started 5-1 2003
 Date completed 5-15 2003

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>AIR LIFT</u>	<u>30</u>	<u>90' air line</u>	<u>3 HRS</u>