COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92063
Permit No.
Basin 105

NOTICE OF INTENT NO. 49726

1. OWNER CURTIS HOFFMAN
MAILING ADDRESS 1420DOUGLAS AVE #12
GARDNERVILLE, NV 89410

ADDRESS AT WELL LOCATION 1370 EASTVALLEY RD
GARDNERVILLE, NV 89410

2. LOCATION SE ¼ SE ¼ Sec 2 T 12 N R 20 E DOUGLAS County

PERMIT NO. (Issued by Water Resources) | Parcel No. 1220-02-001-010 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
HARD PAN CLAY		0	5	5
COURSE GRAVELS		5	13	8
COBBLES AND SMALL GRAVELS		13	116	108
BROWN CLAY		116	165	57
SMALL GUMMY CLAY CLAY STRATA		165	173	8
BROWN CLAY WITH SMALL GRAVELS		173	205	32
GUMMY CLAY		205	215	10
FRACTURED GRAVELS SMALL OBSIDIAN SANDS	XXX	215	250	35

Date started 1/16, 20 04
Date completed 1/18, 20 04

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	50	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 250' Feet Depth Cased 250' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	250 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	250

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3 X 3/32
From 230 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 100 ☒ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 250 feet

9. WATER LEVEL
Static water level 90 feet below land surface
Artesian flow G.P.M 30 P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING & PUMPS INC. (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 55548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Rick Crane
By driller performing actual drilling on site or contractor
Date 1/24/03

(Rev 3-91) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk, Inc. · Dallas, Texas · (214) 340-9429