

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 48441

1. OWNER JIM & SHARON BRASHER ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 2435 Faretto Lane 425 Dusty Lane
Reno, Nevada 89511 Reno, Nevada 89439
 2. LOCATION NW SE 18 T 19N N/S R 18 E Washoe County
 PERMIT NO. 030-082-19 033-082-26 Verdi area
 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Boulders, gravels some clay		1	12	11
Gray sandy clays		12	21	9
Dark brown sandy clays		21	46	25
Gray sandy clays		46	118	72
Soft zone	X	118	121	3
Gray sandy clays		121	135	14
Dark brown sandy clays		135	147	12
Soft zone	X	147	151	4
Dark brown sandy clay		151	157	6
Soft zone	X	157	161	4
Gray, green volcanic rock very hard		161	168	7
Gray sandy clays		168	175	7
Soft zone	X	175	185	10
Gray sandy clays		185	193	8
Soft zone	X	193	213	20
Gray sandy clays		213	222	9
Soft zone	X	222	229	7
Gray sandy clays		229	239	10
Soft zone	X	239	246	7
Gray sandy clays		246	251	5

8. WELL CONSTRUCTION
 Depth Drilled 251 Feet Depth Cased 251 Feet
 HOLE DIAMETER (BIT SIZE)
 From 9 7/8 Inches To 0 Feet 251 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	251

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 151 feet to 251 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Depth of Seal 100 feet Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 100 feet to 251 feet

9. WATER LEVEL
 Static water level 37 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370
RENO, NEVADA 89510
 Nevada contractor's license number 0022549
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed [Signature]
 by driller performing actual drilling on site or contractor
 Date October 15, 2003

Date started October 6, 2003, 19____
 Date completed October 10, 2003, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100+		