

COPIES TO
 DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340



OFFICE USE ONLY

Log No. 92096

Permit No. _____

Basin 089

NOTICE OF INTENT NO. 49702

INTENT OR TYPE ONLY

1. OWNER PAUL FROST
 MAILING ADDRESS _____

ADDRESS AT WELL LOCATION 18200 LAKE VISTA RD
WASHOE VALLEY, CARSON CITY, NV 89704

2. LOCATION NE 1/4 NE 1/4 Sec 3 T 16 N R 19 E WASHOE County

PERMIT NO. 055-081-83
 Issued by Water Resources _____ Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVERBURDEN		0	3	3
RUSTY SANDS		3	15	12
COURSE DG SANDS	X	15	87	72
SILTY GRAY SANDS	X	87	145	58
SANDY CLAY				
COURSE WHITE & BLACK DG SANDS	XXX	145	180	35

8. WELL CONSTRUCTION

Depth Drilled 180' Feet Depth Cased 180' Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>10 3/4</u> Inches	<u>0</u> Feet <u>180</u> Feet
_____ Inches	_____ Feet _____ Feet
_____ Inches	_____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>180</u>

Perforations:

Type perforation FACTORY MILL SLOT
 Size perforation 3 X 3/32

From 160 feet to 180 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: _____
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 180 feet

9. WATER LEVEL

Static water level _____ 5 feet below land surface
 Artesian flow _____ G.P.M. 25+ P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name CAPITAL CITY WELL DRILLING INC.
 (CONTRACTOR)
 Address 20 KIT KAT DRIVE
 (CONTRACTOR)
CARSON CITY, NV 89706
 Nevada contractor's license number issued by the State Contractor's Board 55548
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157

Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 10/15/03

Date started 9/22, 20 03
 Date completed 9/23, 20 03

7. WELL TEST DATE

TEST METHOD:	Bailer	Pump	Air Lift
	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Draw Down (Feet Below Static)		Time (Hours)
G.P.M.			
<u>25+</u>	<u>35</u>	<u>3 HRS</u>	

RECEIVED
 13 OCT 28 AM 10:54
 STATE ENGINEERS OFFICE