WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92088
Permit No.
Basin 085

NOTICE OF INTENT NO. 48446

1. OWNER CHUCK LIVELY
MAILING ADDRESS 1661 Topeka Cir.
Sparks, Nevada 89434

ADDRESS AT WELL LOCATION 7915 Starhill Way
Sparks, Nevada 89436

2. LOCATION NW ¼ NE ¼ Sec. 4 T. 20N N/S R. 20 E. Washoe County
PERMIT NO. (Issued by Water Resources) 083-440-36 (Parcel No.) Spanish Springs V. Ranchos (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown sandy clays		1	9	8
Sand & gravel cemented		9	11	2
Brown sandy clays some gravels		11	39	28
Brown clays		39	94	55
Soft zone		94	97	3
Brown sandy clays		97	121	24
Soft zone (app. 2 GPM)	X	121	124	3
Brown sandy clays		124	130	6
Soft zone (app. 2 GPM)	X	130	136	6
Brown sandy clays		136	151	15
Soft zone, med to coarse sands	X	151	156	5
Brown sandy clays		156	181	25
Soft zone, med to coarse sands	X	181	189	8
Brown sandy clays		189	200	11

Date started December 3, 2003, 19
Date completed December 4, 2003, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	50 Feet	
8 5/8 Inches	50 Feet	200 Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	200

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 155 feet to 195 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 feet
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 90 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 0022549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed (By driller performing actual drilling on site or contractor)
Date December 8, 2003

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627