WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92095
Permit No.
Basin 101

NOTICE OF INTENT NO. 54525

OWNER Frank Woolsey
MAILING ADDRESS 2161 W. Williams Ave.
Fallon, NV 89406

ADDRESS AT WELL LOCATION 4238 Falcon Dr. Fallon
Nv.

2. LOCATION NW 1/4 NW 1/4 Sec. 28 T 19 N/S R 28 E churchill County
PERMIT NO. Issued by Water Resources
008-282-56 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown sand		0	6	6
Brown clay		6	17	11
brown sand		17	25	8
brown clay		25	40	15
gray clay		40	46	6
gray sand		46	50	4
gray sand		50	52	2
gray sand		52	58	6
brown sand		58	65	7
gray clay		65	70	5
brown sand	xx	70	74	4

Date started 9/26/2003, 19__
Date completed 9/26/2003, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1 hr

8. WELL CONSTRUCTION
Depth Drilled 74 Feet Depth Cased 74 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	74 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	0	20
6 PVC	3.92	.258	20	74

Perforations:
Type perforation mill cut
Size perforation 1/8
From 67 feet to 74 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 74 feet

9. WATER LEVEL
Static water level 16 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. Contractor
Address P.O. Box 1265 Contractor
Fallon, Nv. 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2212
Signed Norman Parsons
By driller performing actual drilling on-site or contractor
Date 10/21/2003

USE ADDITIONAL SHEETS IF NECESSARY