WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92097
Permit No.
Basin 76

NOTICE OF INTENT NO. 54437

1. OWNER CRAIG KING
MAILING ADDRESS 2040 FARM DISTRICT ROAD
FALLON, NV 89406

ADDRESS AT WELL LOCATION 785 CORRIENTE COURT

2. LOCATION SE 1/4 NE 1/4 Sec. 15 T 20 N/S R 24 E Lyon ~~CHURCHILL~~ County
PERMIT NO. Issued by Water Resources
Parcel No. 21-151-29
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	
BROWN SAND		1	19	18
BROWN CLAY		19	40	21
BROWN SAND		40	50	10
BROWN CLAY		50	80	30
MC GRAVELS	X	80	120	40
SEALED WITH NEAT CEMENT&AQUAGUARD				

Date started 10/20/~~1903~~ 2003, 19__
Date completed 10/24/~~1903~~ 2003, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1 HR

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	50	Feet
6 1/8	Inches	50	Feet	120	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	120

Perforations:
Type perforation MACHINE SLIT
Size perforation .080
From 113 feet to 118 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WELSCO CORP. Contractor
Address P. O. BOX 888 Contractor
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
Signed By driller performing actual drilling on-site or contractor
Date 11/21/03

USE ADDITIONAL SHEETS IF NECESSARY