


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



OFFICE USE ONLY
 Log No. 92101

Permit No. _____
 Basin 085

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

19AAA

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **54457**

1. OWNER Jason Thrailkill
 MAILING ADDRESS 601 Calle De La Plata Dr.
Sparks, NV 89436

ADDRESS AT WELL LOCATION 601 Calle De La Plata Dr.

2. LOCATION NE 1/4 NE 1/4 Sec. 19 T 21N
 PERMIT NO. _____
 Issued by Water Resources 076-371-55
 Parcel No. _____

N/S R 21E E Washoe County
 Subdivision Name Spanish Springs Ranchos Unit 2, 19-11-3 per A

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<p>On this date we abandoned the 6 5/8" domestic water well according to approved methods from Michael Anderson, Dept. of Water Resources. We were able to perforate the casing from about 105' to 48' where we hit the sanitary well seal. We perforated using a Mills Knife at 4 around and at 1 foot intervals. We then poured approximately 4 yards of neat cement mixed 5.2 gallons/sack. This abandonment method was used due to a stuck pump/pipe/wire in the well which precluded us from perforating below where the wire was "balled up" and the 1 1/4" galv. pipe had been severed due to the stuck pump in the well.</p>				
<p>Washoe Co. Permit #WL030224</p>				
<p>19-11-3</p>				

8. WELL CONSTRUCTION

Depth Drilled _____ Feet Depth Cased _____ Feet
HOLE DIAMETER (BIT SIZE)
 From _____ To _____
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>				

Perforations:
 Type perforation Mills Knife
 Size perforation Puncture
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal _____ Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level Below 368' ? feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc.
 Contractor
 Address 1600 Mt. Rose Hwy
 Contractor
Reno, NV 89511
 Nevada contractor's license number issued by the State Contractor's Board 23096
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
 Signed R. Bruce MacKay
 By driller performing actual drilling on-site or contractor
 Date 10/8/03

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	