

Log No. 4245  
 Permit No. \_\_\_\_\_  
 Basin 294

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 48554

1. OWNER Mark Wood & Arleen Neale ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 6041 N. Myrtle Rd 14465 Hope Lane  
Myrtle Creek OR 97457 Reno NV 89506  
 2. LOCATION NE 1/4 SE 1/4 Sec. 7 T. 22 S. 19 E. Washoe County  
 PERMIT NO. 079-382-75 Red Rock Estates, lot 94, par. 3  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other M.V.D.

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay & Sand		0	30	30
Clay		30	45	15
Sand		45	55	10
Clay		55	85	30
Clay & Sand layers		85	120	35
Clay		120	150	30
Sand		150	160	10
Clay		160	180	20
Clay & Sand layers		180	220	40
Clay		220	235	15
Course Sand		235	250	15
Clay		250	260	10
Clay & Sand layers		260	275	15
Clay		275	325	15

8. WELL CONSTRUCTION  
 Depth Drilled 325 Feet Depth Cased 325 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 0 Feet 325 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>3/16</u>	<u>2+</u>	<u>325</u>

Perforations:  
 Type perforation Saw slot  
 Size perforation 3/16  
 From 105 feet to 125 feet  
 From 145 feet to 165 feet  
 From 185 feet to 285 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 325 feet

9. WATER LEVEL  
 Static water level 63 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature NA °F Quality NA

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Olencki Drilling & Pump Co.  
 Address 15045 Red Rock Rd  
Reno NV 89506  
 Nevada contractor's license number 50343  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1656  
 Division of Water Resources, the on-site driller  
 Signed John F. Olencki  
 By driller performing actual drilling on site or contractor  
 Date 11/2/03

Date started 10/14, 2003  
 Date completed 10/23, 2003

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>60</u>	<u>300</u>	<u>4</u>