

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT



office use only  
Log No. 92111  
Permit No. ....  
Basin. 093

NOTICE OF INTENT NO 51558

275DA

OWNER Jeff Wagner  
MAILING ADDRESS 1360 Half Mine Rd  
Reno NV

ADDRESS AT WELL LOCATION 1360 Half Mine Rd

2. Location SE 1/4 NW 1/4 Sec 27 T 22N R 19E Washoe County  
PERMIT NO. PARCEL NO. 079-450-31 SUBDIVISION NAME

3. WORK PERFORMED | 4. PROPOSED USE | 5. WELL TYPE  
X New Well Replace Recondition | X Domestic Irrigation Test | Cable X Rotary RVC  
Deepen Abandon Other | Municipal/Industrial Monitor Stock | X Air Other Mud

6. LITHOLOGIC LOG					8. WELL CONSTRUCTION				
Material	Water Strata	From	To	Thickness	Depth Drilled	HOLE DIAMETER (BIT SIZE)	From	To	Depth Cased
Clay & rock.		0	25	25	10 5/8 inches		0	60	498 feet
Sands.		25	30	5	8 3/4 inches		60	498	feet
Rock & clay.		30	460	430					feet
Fractured rock.		460	498	38					feet

CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.94	188	+1 1/2	498

Perforations:

Type Perforation	From	To
Factory	458 feet	498 feet
Size perforation 3/32 x 3"		
	From	feet to

Surface Seal X YES No Seal Type:  
Depth of Seal 55 feet Neat Cement  
Pumped Cement Grout  
x Poured X Concrete Grout

Gravel Packed: X Yes No  
From 55 feet to 498 feet

9. WATER LEVEL  
Static water level 330 feet below land surface  
Artesian flow 0 GPM 0 P.S.I.  
Water Temperature cold Degrees F Quality

Date started 9-12 -03  
Date completed 9-23 -03

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	x	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (hours)		
10	20			
30	70			
30	170			

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name McKay Drilling, Inc.  
2290 Pioneer Drive  
Reno, NV 89509  
NV Contractors No. 14170  
NV Driller's Lic (on site) 786  
Signed   
By driller performing actual drilling on site or contractor  
Date 9-24 -03

RECORDED  
2003 OCT 10 AM 11:55  
STATE ENGINEERING OFFICE