

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 92162
 Permit No. _____
 Basin. 104

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 53389
 NW CORNER of intersection
 of Lompas and North Ridge

1. OWNER LAS VEGAS PAYING
 MAILING ADDRESS 4420 S. Decatur
Las Vegas NV
 ADDRESS AT WELL LOCATION _____
 2. LOCATION SW 1/4 NW 1/4 Sec. 09 T. 15 N. S. R. 20 E County _____
 PERMIT NO. DEW-43 Parcel No. _____ Subdivision Name CARSON CITY, NV

3. WORK PERFORMED DEWATERING 4. PROPOSED USE TEMP DEWAT. 5. WELL TYPE
 New Well Replace Recondition Domestic Irrigation Test Cable Rotary RVC
 Deepen Abandon Other _____ Municipal/Industrial Monitor Stock Air Other BUCKET

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Fill</u>		<u>0</u>	<u>3</u>	
<u>SAND</u>	<u>8'</u>	<u>3</u>	<u>15</u>	
<u>Silty Sand</u>		<u>15</u>	<u>25</u>	
<u>clay/sand mix</u>		<u>25</u>	<u>40</u>	

RECEIVED
 04 FEB 11 PM 4:34
 STATE ENGINEERS OFFICE

DCNR/DWR
 RECEIVED
 FEB 19 2004

LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 40 Feet Depth Cased 40 Feet
 HOLE DIAMETER (BIT SIZE)
 From 24 Inches 0 Feet 40 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6"</u>	<u>SDR-21</u>	<u>F-480</u>	<u>0</u>	<u>40</u>

Perforations:
 Type perforation slot
 Size perforation 1.032
 From 10 feet to 40 feet
 From _____ feet to _____ feet

Surface Seal: Yes No 2ft Bentonite seal
 Depth of Seal 0.5 to surface Seal Type:
 Neat Cement Cement Grout Concrete Grout
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 0.5 feet to 40 feet

9. WATER LEVEL
 Static water level: 8' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality good

Date started 2-6 NOV
 Date completed 2-6 NOV

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Griffin Dewatering Contractor
 Address 560 E. MARIANA Contractor
Ontario Cal. 92671
 Nevada contractor's license number 32440 31246
 issued by the State Contractor's Board:
 Nevada driller's license number issued by the ABDS-2150
 Division of Water Resources, the on-site driller.
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 2-6-04