

COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
 Log No. 92180  
 Permit No. \_\_\_\_\_  
 Basin 212  
 NOTICE OF INTENT NO. 25828

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

PRINT OR TYPE ONLY

1. OWNER BEAZER HOMES HOLDING CORP ADDRESS AT WELL LOCATION Tropicana & Broadbent  
 MAILING ADDRESS 4670 S FORT APACHE RD #200 LAS VEGAS, NV 89147  
LAS VEGAS, NV 89147

2. LOCATION NW 1/4 NE 1/4 Sec 27 T 21 S R 61 E CLARK County

PERMIT NO. DW-1172 161-27-510-005  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other Dewater  
 4. PROPOSED USE Dewater  
 Domestic  Irrigation  Test  Monitor  Stock  
 Municipal/Industrial  Other

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<b>4-dewater wells</b>				
Depth 40'				
Sandy clay		0	8'	
Silt	XX	8'	21'	
Silt/Gray clay	X	21'	40'	
DCNR/DWR RECEIVED				
FEB 17 2004				
LAS VEGAS OFFICE				

8. WELL CONSTRUCTION

Depth Drilled 40' Feet Depth Cased 40' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
24 Inches 0 Feet 40 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
	36.71	.0250	0	40

Perforations:  
 Type perforation Machine  
 Size perforation 1/4 x 2.5 x 3 rows @ 13  
 From 0 feet to 40 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Depth of Seal \_\_\_\_\_  Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 1/28, 20 04  
 Date completed 1/28, 20 04

7. WELL TEST DATE

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL

Static water level 18' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name ALLEN DRILLING INC.  
 (CONTRACTOR)  
 Address 4015 WEST TOMPKINS AVE.  
 (CONTRACTOR)  
LAS VEGAS, NV 89103  
 Nevada contractor's license number issued by the State Contractor's Board 0018916 & 0018917  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1301  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 2/9/04