WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92188
Permit No.
Basin 039

NOTICE OF INTENT NO. 42232

1. OWNER Nevada Dept. of Enviromental Protedtion
MAILING ADDRESS 333 West Nye Lane
Carson City, NV 89706

ADDRESS AT WELL LOCATION 2miles north of Jarbridge, NV. at landfill

2. LOCATION SW 1/4 SW 1/4 Sec. 5 T 46 N/S R 58 E Elko County
PERMIT NO. _____ Issued by Water Resources
Parcel No.
At regional landfill Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
MW#1: Measured water level at 12.2'. Depth of well 20.1'. Mixed 2 bags of portland type 2 cement and 10 gallons of water and pumped in from bottom of well to surface.				
MW#2: Measured water level at 13.9'. Depth of well 19.89'. Mixed 3 bags of portland type 2 cement and 15 gallons of water and pumped in from bottom of well to surface.				
MW#3: Measured water level at 9.6'. Depth of well 14.0'. Mixed 4 bags of neat cement and 20 gallons of water and pumped in from bottom of well to surface.				
All wells combined shoild have only required 3 cubic ft. of cement but actually required 9 cubic feet.				

Date started 11/13/2002, 19__
Date completed 11/13/2002, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled _____ Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	pvc	sch. 40	0	20'

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 20',20',14'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 1-9.6,2-13.9,3-12.2' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Carson Pump Contractor
Address P.O. Box 20159 Contractor
Carson City, NV. 89712
Nevada contractor's license number issued by the State Contractor's Board 39920
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
Signed Dan Grange
By driller performing actual drilling on-site or contractor
Date 11/20/2002

USE ADDITIONAL SHEETS IF NECESSARY