

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 92192
 Permit No. _____
 Basin 101

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **54455**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER **AKINS CONSTRUCTION**
 MAILING ADDRESS **2160 RICE ROAD**
FALLON, NV 89406

ADDRESS AT WELL LOCATION **845 HUNTER PARKWAY**

2. LOCATION NW 1/4 NW 1/4 Sec. 30 T 19
 PERMIT NO. _____
 Issued by Water Resources _____ Parcel No. 8-3/4-55

N/S R 28 E CHURCHILL County

Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	
BROWN SAND		1	15	14
BROWN CLAY		15	18	3
BROWN SAND		18	27	9
BROWN CLAY		27	30	3
GRAY SAND/CLAY		30	50	20
BLACK SILT		50	73	23
GRAY SAND		73	90	17
GRAY CLAY		90	92	2
BROWN SAND	X	92	106	14

8. WELL CONSTRUCTION
 Depth Drilled 106 Feet Depth Cased 106 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
<u>10 3/4</u> Inches	<u>0</u> Feet	<u>96</u> Feet
<u>6</u> Inches	<u>96</u> Feet	<u>106</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>.188</u>	<u>+2</u>	<u>106</u>

Perforations:
 Type perforation MACHINE SLIT
 Size perforation .080
 From 100 feet to 105 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 95 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 15 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WELSCO CORP. Contractor

Address P. O. BOX 888 Contractor

FALLON, NV 89406
 Nevada contractor's license number issued by the State Contractor's Board 11752

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199

Signed [Signature] By driller performing actual drilling on-site or contractor
 Date 11/21/03

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>		<u>1HR</u>

Date started 10/25/1903 2003, 19
 Date completed 10/26/1903 2003, 19