WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92228
Permit No.
Basin 02

NOTICE OF INTENT NO. 54393

1. OWNER MIKE CASEY
MAILING ADDRESS 1550 ALLEN ROAD
FALLON, NV 89406

ADDRESS AT WELL LOCATION 2215 ANTELOPE

2. LOCATION SW 1/4 NE 1/4 Sec. 20 T 17 N/S R 25 E LYON County
PERMIT NO. (Issued by Water Resources) 17-463-12 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN SAND		1	15	15
HARD PAN		15	18	3
BROWN SAND		18	50	32
BROWN CLAY		50	60	10
GREY SAND		60	80	20
GRAY CLAY		80	95	15
GRAY SILT/CLAY		95	130	35
GRAY SAND/GRAVEL		130	180	50
GRAY CLAY		180	192	12
BROWN SAND/GRAVELS	X	192	208	16

RECEIVED 04 FEB 18 AM 10:59 STATE ENGINEERS OFFICE

Date started 1/28/~~1904~~ 28, 19__
Date completed 1/29/~~1904~~ 29, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40		1 HR

8. WELL CONSTRUCTION
Depth Drilled 208 Feet Depth Cased 208 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	50	Feet
6 5/8	Inches	50	Feet	208	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	208

Perforations:
Type perforation MACHINE SLOT
Size perforation .080
From 201 feet to 206 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50 AQUAGUARD
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 35 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WELSCO CORP. (Contractor)
Address P. O. BOX 888 (Contractor)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
Signed (By driller performing actual drilling on-site or contractor)
Date 2/9/2004

USE ADDITIONAL SHEETS IF NECESSARY