WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92232
Permit No.
Basin 101

NOTICE OF INTENT NO. 54391

OWNER AKINS CONSTRUCTION
MAILING ADDRESS 2160 RICE ROAD
FALLON, NV 89406

ADDRESS AT WELL LOCATION 646 SUNRISE TERRACE

2. LOCATION SW 1/4 SW 1/4 Sec. 24 T 19 N/S R 28 E CHURCHILL County
PERMIT NO. Issued by Water Resources
008-312-42 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SDOIL		0	1	
BROWN SAND		1	20	19
BROWN CLAY		20	22	2
BROWN SAND		22	40	18
GRAY SAND		40	65	25
GRAY CLAY		65	70	5
BROWN SAND		70	85	15
GRAY CLAY		85	90	5
GRAY SAND		90	130	40
GRAY CLAY		130	133	3
GRAY SAND		133	190	57
BROWN CLAY		190	192	2
BROWN SAND	X	192	207	15

Date started 1/12/~~1904~~ 20, 19__
Date completed 1/16/~~1904~~ 20, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1 HR

8. WELL CONSTRUCTION
Depth Drilled 207 Feet Depth Cased 207 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	100	Feet
6 1/8	Inches	100	Feet	207	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	207

Perforations:
Type perforation MACHINE SLOT
Size perforation .080
From 200 feet to 205 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 32' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WELSCO CORP. Contractor
Address P. O. BOX 888 Contractor
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
Signed By driller performing actual drilling on-site or contractor
Date 2/14/200

USE ADDITIONAL SHEETS IF NECESSARY