WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92237
Permit No.
Basin 157B

NOTICE OF INTENT NO. 51149

1. OWNER Round mt Gold Corp
MAILING ADDRESS P.O. Box 480
Round Mt Nevada 89045

ADDRESS AT WELL LOCATION Gold Hill
GHA-03-26

2. LOCATION SW ¼ SE ¼ Sec. 25 T. 11 N/S R. 43 E. Nye County

PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic Dual ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Red Silt Sands + Small Clay Zones		0	140	140
Brown Gravel		140	160	20
#8 Sand 4/6 Bags 50#		130	160	30
Medium Hole Plug 2500#		50	130	80
Cement 17-94# Bags		43	50	53

Date started 12-6, 2003
Date completed 12-9, 2003

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10	N/A	12 hrs

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
14 3/4 Inches		0 Feet	20 Feet
8 3/4 Inches		20 Feet	160 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10		3/16 wall	+3	20
4"	sch	80 PVC	+3	140
1"	sch	40 PVC	+3	140

Perforations:
Type perforation Horiz Slot
Size perforation .020
From 4" sch 80 pvc 140 feet to 160 feet
From 1" sch 40 pvc 140 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 130 feet to 160 feet

9. WATER LEVEL
Static water level 133 feet below land surface
Artesian flow None G.P.M. P.S.I.
Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Co Inc (Contractor)
Address P.O. Box 2748 (Contractor)
Elko Nevada 89803
Nevada contractor's license number issued by the State Contractor's Board 0030823
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1879
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 12-9-03

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627