WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92238
Permit No.
Basin 137B

NOTICE OF INTENT NO. 51153

1. OWNER Round Mt Gold Corp
MAILING ADDRESS P.O. Box 480
Round Mt Nevada 89045

ADDRESS AT WELL LOCATION Gold Hill
GHR-0704

2. LOCATION NE ¼ NW ¼ Sec. 33 T. 11 (N)S R 44 E Nye County

PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock
Dual

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Hard Brown Rock		0	120	120
Grey Hard Rock		120	280	160
Grey Fractured		280	300	20
Grey Hard Rock some Fracturing		300	360	60
Approx 25 GPM				
1" sch 40 PVC Blank		+3	320	
1" sch 40 PVC Blank		340	360	
1" sch 40 PVC Screen		320	340	
1-2500# Bag #8 Sand		310	360	50
2-2500# Bags Medium Hole plug		30	310	280
12-94# Bags Cement		+3	30	33

Date started 12-11, 2003
Date completed 12-13, 2003

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	N/A	

8. WELL CONSTRUCTION
Depth Drilled 360 Feet Depth Cased 360 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
14 3/4 Inches	0 Feet	20 Feet
9 Inches	20 Feet	360 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10		3/16 Wall	+3	20
4"	sch	80 PVC	+3	320
4"	sch	80 PVC	340	360

Perforations:
Type perforation Horz Slot
Size perforation .020
From 320 feet to 340 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 30
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 310 feet to 360 feet

9. WATER LEVEL
Static water level 249 feet below land surface
Artesian flow Non G.P.M. P.S.I.
Water temperature Cold °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Co Inc (Contractor)
Address P.O. Box 2746 (Contractor)
Elko Nevada 89803
Nevada contractor's license number issued by the State Contractor's Board 0030823
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1879
Signed (By driller performing actual drilling on site or contractor)
Date 12-13-03

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627