

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 57151

1. OWNER Round Mt Gold Corp ADDRESS AT WELL LOCATION Gold Hill  
 MAILING ADDRESS po Box 480  
Round Mt Nevada 89045 6300 GHA-03-05

2. LOCATION NW 1/4 NW 1/4 Sec. 33 T. 11 N. S. R. 44 E. Nye County

PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Hard Rock Brown yellow + white</u>		<u>0</u>	<u>280</u>	<u>280</u>
<u>Fractured</u>		<u>280</u>	<u>300</u>	<u>20</u>
<u>Hard Grey Rock</u>		<u>300</u>	<u>380</u>	<u>80</u>
<u>Approx 25 GPM</u>				
<u>1" sch 40 PVC Blank</u>		<u>13</u>	<u>340</u>	
<u>1" sch 40 PVC Screen</u>		<u>340</u>	<u>360</u>	
<u>1" sch 40 PVC Blank</u>		<u>360</u>	<u>380</u>	
<u>40-50# Bags #8 Sand</u>		<u>330</u>	<u>380</u>	<u>50</u>
<u>2-2500# Bags Medium Holo-phys</u>		<u>30</u>	<u>330</u>	<u>300</u>
<u>12-94# Bags Cement</u>		<u>13</u>	<u>30</u>	<u>17</u>

8. WELL CONSTRUCTION  
 Depth Drilled 380 Feet Depth Cased 380 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
<u>14 3/4</u>	<u>0</u>	<u>20</u>
<u>9</u>	<u>20</u>	<u>380</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10</u>		<u>3/16 wall</u>	<u>13</u>	<u>20</u>
<u>4" sch 80</u>	<u>80</u>	<u>PVC</u>	<u>13</u>	<u>340</u>
<u>4" sch 80</u>	<u>80</u>	<u>PVC</u>	<u>360</u>	<u>380</u>

Perforations:  
 Type perforation Horiz Slot  
 Size perforation .020

From 340 feet to 360 feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 30  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 330 feet to 380 feet

9. WATER LEVEL  
 Static water level 219 feet below land surface  
 Artesian flow Non G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature Cold °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge

Name Ekland Drilling Co Inc Contractor  
 Address P.O. Box 2749 Contractor  
Elko Nevada 89803

Nevada contractor's license number issued by the State Contractor's Board 0030823  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1879

Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 12-11-03

Date started 12-9, 2003  
 Date completed 12-11, 2003

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25</u>	<u>N/A</u>	<u>4</u>