WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92957
Permit No.
Basin 99

NOTICE OF INTENT NO. 48561

1. OWNER Duke & Nadine Deaney
MAILING ADDRESS P.O. Box 157 Verdi NV 89439
ADDRESS AT WELL LOCATION 22000 Red Rock Rd. Reno NV 89506

2. LOCATION SE ¼ SE ¼ Sec. 32 T. 24 N/S R. 18 E. Washoe County
PERMIT NO. ____ Issued by Water Resources
078-292-01 Parcel No.
Rancho Haven Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	17	17
Clay		17	25	8
Sand		25	105	80
Clay		105	125	20
Rocks		125	130	5
Sand & Clay layers		130	175	45
Sand Course		175	202	27
Clay Hard		202	217	15
Sand Course		217	240	23

Date started 2/9, 2004
Date completed 2/11, 2004

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	180	6

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11 Inches	0 Feet	240 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	3/16	2+	240

Perforations:
Type perforation Saw slot
Size perforation 3/16
From 180 feet to 200 feet
From 220 feet to 240 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 240 feet

9. WATER LEVEL
Static water level 5 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature NA °F Quality NA

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Olenski Drilling & Pump Co. (Contractor)
Address 15045 Red Rock Rd (Contractor)
Reno NV 89506
Nevada contractor's license number issued by the State Contractor's Board 50343
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1656
Signed John F Olenski (By driller performing actual drilling on site or contractor)
Date 2/14/04

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627