WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92262
Permit No.
Basin 105

NOTICE OF INTENT NO. 49316

1. OWNER Robert & Joan Waugh
MAILING ADDRESS 1630 Valancia Ave.
Stockton, CA 95206

ADDRESS AT WELL LOCATION 2336 Genoa St. Genoa NV.

2. LOCATION NE 1/4 SW 1/4 Sec. 9 T 13N N/S R 19E E Douglas County
PERMIT NO. Issued by Water Resources
1319-09-602-006 Parcel No.
Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Black gray rock		0	90	90
Volcanic rock		90	94	4
Black & gray fractured rock some purple	x	94	140	46
Green granite fractured	x	140	180	40
Fractured rock gravel	x	180	251	71

RECEIVED 04 FEB 9 AM 11:16 STATE ENGINEERS OFFICE

Date started 1/21/2004, 19__
Date completed 1/23/2004, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+		3

8. WELL CONSTRUCTION
Depth Drilled 251 Feet Depth Cased 251 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	50	Feet
9 7/8	Inches	50	Feet	251	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	251

Perforations:
Type perforation Machine cut
Size perforation 3/32 x 3
From 211 feet to 251 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No.
From 50 feet to 251 feet

9. WATER LEVEL
Static water level 147 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc.
Contractor
Address 1600 Mt. Rose Hwy
Contractor
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 1/26/04

USE ADDITIONAL SHEETS IF NECESSARY