WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 72262
Permit No.
Basin 105

NOTICE OF INTENT NO. 54494

1. OWNER Northstar Construction
MAILING ADDRESS 170 Cogorno Way
Carson City, NV 89703

ADDRESS AT WELL LOCATION 4105 Golden Eagle Lane

2. LOCATION SE 1/4 SW 1/4 Sec. 3 T 14N N/S R 20E E Carson County
PERMIT NO. (Issued by Water Resources) | Parcel No. 10-491-20 | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Coarse sand brown some fine sand layers		0	135	135
Brown sand with layers of clay	x	135	200	65
Carson well permit # 03-00000817				

RECEIVED 04 FEB 27 AM 11:35 STATE ENGINEERS OFFICE

Date started 1/12/2004, 19__
Date completed 1/14/2004, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		3

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	200 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	200

Perforations:
Type perforation Machine cut
Size perforation 3/32 x 3
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 104
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 104 feet to 200 feet

9. WATER LEVEL
Static water level 75 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce Mackay (By driller performing actual drilling on-site or contractor)
Date 1/14/04

USE ADDITIONAL SHEETS IF NECESSARY