

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 92271
 Permit No. _____
 Basin 105
 NOTICE OF INTENT NO. 19730

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

PRINT OR TYPE ONLY

1. OWNER KELLY CHASE (RAY PARODIE CONT.) ADDRESS AT WELL LOCATION 1665 SOUTH BENTON GARDNERVILLE, NV 89410
 MAILING ADDRESS 1073 CORTEZ GARDNERVILLE, NV 89410

2. LOCATION NW 1/4 SW 1/4 Sec 26 T 13 N R 20 E DOUGLAS County
 PERMIT NO. 1320-26-022-006

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
OVER BURDEN		0	3	3
HARD PAN CLAY		3	9	6
COURSE DG GRAVELS		9	45	36
BROWN CLAY		45	110	65
SMALL OBSIDIAN GRAVELS		110	162	525
BROWN GUMMY CLAY		162	203	41
FRACTURED GRAVELS				
SMALL SILTY SAND LAYERS	XXX	203	240	37

8. WELL CONSTRUCTION
 Depth Drilled 240 Feet Depth Cased 240 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 3/4 Inches To 0 Feet
0 Feet 240 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	240

Perforations:
 Type perforation FACTORY MILL SLOT
 Size perforation 3 X 3/32
 From 220 feet to 240 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 240 feet

9. WATER LEVEL
 Static water level 80 feet below land surface
 Artesian flow _____ G.P.M. 25 P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name CAPITAL CITY WELL DRILLING
 (CONTRACTOR)
 Address 20 KIT KAT DRIVE
 (CONTRACTOR)
CARSON CITY, N V89410
 Nevada contractor's license number issued by the State Contractor's Board 0055548
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
 Signed Rick Crane
 By driller performing actual drilling on site or contractor
 Date 2/25/04

Date started 2/19, 20 04
 Date completed 2/21, 20 04

7. WELL TEST DATE

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

RECEIVED
 04 FEB 25 AM 10:55
 STATE ENGINEERS OFFICE