


COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 72272  
 Permit No. \_\_\_\_\_  
 Basin 105



PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 49925

1. OWNER **B & R CONSTRUCTION**  
 MAILING ADDRESS 1665 TOLER LN  
GARDNERVILLE, NV 89410

ADDRESS AT WELL LOCATION 1668 PINENUT RD  
GARDNERVILLE, N V89410

2. LOCATION NW 1/4 SE 1/4 Sec 11 T 12 N R 20 E **DOUGLAS** County

PERMIT NO. 1220-11-001-002  
 Issued by Water Resources \_\_\_\_\_ Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other **MUD**

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BROWN CLAY		0	3	3
COBBLES		3	27	24
COBBLES & GRAVEL		27	68	41
BROWN CLAY		68	72	4
SMALL GRAVELS	XXX	72	130	58

8. WELL CONSTRUCTION  
 Depth Drilled 130' Feet Depth Cased 130' Feet

HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
10 5/8 Inches 0 Feet 130 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	130

Perforations:  
 Type perforation FACTORY MILL SLOT  
 Size perforation 3X3/32

From 110 feet to 130 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type: \_\_\_\_\_  
 Depth of Seal 100'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 100 feet to 130 feet

9. WATER LEVEL  
 Static water level 30' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 20 P.S.I.  
 Water temperature GOOD °F Quality COLD

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name CAPITAL CITY WELL DRILLING  
 (CONTRACTOR)  
 Address 20 KIT KAT DRIVE  
 (CONTRACTOR)  
CARSON CITY, N V89706  
 Nevada contractor's license number \_\_\_\_\_  
 issued by the State Contractor's Board 0055548  
 Nevada driller's license number issued by the  
 Division of Water Resources, the on-site driller 2157

Signed Kirk Crane  
 By driller performing actual drilling on site or contractor  
 Date 2/9/04

Date started 1/14, 20 04  
 Date completed 1/15, 20 04

7. WELL TEST DATE

TEST METHOD:  Bailor  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>	<u>40</u>	<u>3 HRS</u>

RECEIVED  
 04 FEB 25 AM 10:55  
 STATE ENGINEERS OFFICE