COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 9223
Permit No.
Basin 105

NOTICE OF INTENT NO. 49727

1. OWNER MIKE HICKEY CONSTRUCTION
MAILING ADDRESS 1700 COUNTY RD A
MINDEN, NV 89423

ADDRESS AT WELL LOCATION 1051 WATERLOO LN
GARDNERVILLE, N V89410

2. LOCATION NW ¼ NW ¼ Sec 8 T 12 N R 20 E DOUGLAS County

PERMIT NO. (Issued by Water Resources) 1220-08-000-001 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN CLAY		0	5	5
COURSE SANDS AND GRAVELS		5	13	8
COURSE GRAVELS		13	38	25
LARGE GRAVELS		38	93	55
SMALL LAYER CLAY		93	108	15
SMALL GRAVELS		108	121	13
FRACTURED GRAVELS SAND SANDS	XXX	121	160	39

RECEIVED 04 FEB 25 AM 10:55 STATE ENGINEER'S OFFICE

Date started 2/3, 20 04
Date completed 2/4, 20 04

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+	35	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	160 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	160

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3 X 3/32
From 140 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 100 ☒ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 160 feet

9. WATER LEVEL
Static water level 15 feet below land surface
Artesian flow G.P.M 25+ P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Rick Crane
By driller performing actual drilling on site or contractor
Date 2/15/04

Forms Provided by Forms-On-A-Disk, Inc. · Dallas, Texas · (214) 340-9429