

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 7274
 Permit No. _____
 Basin 105



PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 49724
 ADDRESS AT WELL LOCATION 1851 FISH SPRINGS RD
GARDNERVILLE, NV 89410

1. OWNER DALE ARMSTRONG CONSTRUCTION
 MAILING ADDRESS P.O. BOX 218
GARDNERVILLE, NV 89410

2. LOCATION NW 1/4 NW 1/4 Sec 1 T 12 N R 20 E DOUGLAS County

PERMIT NO. 1220-01-001-054

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thick-ness
OVERBURDEN CLAY		0	5	5
GRAVELS AND CLAY		5	27	22
BROWN CLAY		27	63	36
SMALL SANDS BROWN CLAY		63	135	72
BROWN GUMMY CLAY		135	192	57
FRACTURED GRAVELS	XXX	192	220	28

8. WELL CONSTRUCTION
 Depth Drilled 220' Feet Depth Cased 220 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
10 3/4 Inches 0 Feet 220 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>220</u>

Perforations:
 Type perforation FACTORY MILL SLOT
 Size perforation 3 X 3/32
 From 200 feet to 220 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 220 feet

9. WATER LEVEL
 Static water level 90 feet below land surface
 Artesian flow _____ G.P.M. 25 P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name CAPITAL CITY WELL DRILLING
 (CONTRACTOR)
 Address 20 KIT KAT DRIVE
 (CONTRACTOR)
CARSON CITY, NV 89706
 Nevada contractor's license number issued by the State Contractor's Board 0055548
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
 Signed Rock Crane
 By driller performing actual drilling on site or contractor
 Date 2/9/04

Date started 1/14, 20 04
 Date completed 1/20, 20 04

7. WELL TEST DATE			
TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>	<u>45</u>	<u>3 HRS</u>

RECEIVED
 04 FEB 25 AM 0:55
 STATE ENGINEERS OFFICE