


STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 72275  
 Permit No. 48498  
 Basin 061



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 52579

1. OWNER Barrick Goldstrike Mines AA Well ADDRESS AT WELL LOCATION Barrick Goldstrike minesite, north of Carlin, NV.  
 MAILING ADDRESS P.O. Box 29  
Elko, NV 89803

2. LOCATION SW 1/4 NW 1/4 Sec. 29 T 36N N/S R 50 E Eureka County  
 PERMIT NO. 48498 Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Abandonment procedure was discussed with and approved by DWR prior to doing the work.				
Abandoned by pumping abantonite via tremie from T.D. to 300', where it would rise no further, then poured hole plug while pumping abantonite to 210'. A cement bridge plug was placed to 150', hole plug poured to 20', and capped with neat cement.				
Quantities Used: Cement: 62.8 cu.ft. Hole plug: 210 cu.ft. Abantonite: 427 cu.ft.				

8. WELL CONSTRUCTION  
 Depth Drilled 720 Feet Depth Cased 700 Feet

HOLE DIAMETER (BIT SIZE)  
 From 17.5 Inches To 0 Feet 720 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>12.75</u>	<u>33.04</u>	<u>0.250</u>	<u>+1</u>	<u>720</u>

Perforations:  
 Type perforation Louver; Slot  
 Size perforation 0.125"; 3" x 0.125"

From	To	From	To
<u>Louver: 160</u>	<u>190</u>	<u>Slot: 190</u>	<u>240</u>
<u>Louver: 240</u>	<u>290</u>	<u>Slot: 290</u>	<u>500</u>
<u>Louver: 500</u>	<u>580</u>		

Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 60'  Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured

Gravel Packed:  Yes  No  
 From 60 feet to 720 feet

9. WATER LEVEL  
 Static water level 291 feet below land surface  
 Artesian flow N/A G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling Contractor  
 Address P.O. Box 5279 Contractor  
Elko, NV 89802-5279  
 Nevada contractor's license number issued by the State Contractor's Board 0021976  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1764  
 Signed Paul Bruder  
 By driller performing actual drilling on-site or contractor  
 Date 2/20/04

7. WELL TEST DATA

TEST METHOD	<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	Time (Hours)
<u>24</u>	<u>Draw Down (Feet Below Static)</u>	

Date started 2/19/2004, 19  
 Date completed 2/20/2004, 19

RECEIVED  
 04 MAR - 1 AM 11:24  
 STATE ENGINEERS OFFICE

BSTA

