

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 92080
 Permit No. _____
 Basin 101

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 54439

1. OWNER GEORGIA HILL ADDRESS AT WELL LOCATION 6451 CASEY ROAD
 MAILING ADDRESS 6451 CASEY ROAD
FALLON, NV 89406
 2. LOCATION NE 1/4 SW 1/4 Sec. 30 T 19 N/S R 28 E CHURCHILL County
 PERMIT NO. _____ Issued by Water Resources Parcel No. 611-06 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	1	-147
BROWN SAND		1	20	19
BROWN CLAY		20	25	5
BROWN SAND		25	45	20
BROWN CLAY		45	50	5
GRAY CLAY/SILT		50	82	32
BROWN SAND		82	92	10
GRAY CLAY		92	95	3
GRAY SAND		95	130	35
BROWN CLAY		130	136	6
BROWN SAND	X	136	148	12

8. WELL CONSTRUCTION
 Depth Drilled 148 Feet Depth Cased 148 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 100 Feet
10 3/4 Inches
 From 100 Feet To 148 Feet
6 Inches
 From _____ Feet To _____ Feet
 _____ Inches

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	148

Perforations:
 Type perforation MACHINE SLIT
 Size perforation .080
 From 141 feet to 146 feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal 100
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WELSCO CORP. Contractor
 Address P. O. BOX 888 Contractor
FALLON, NV 89406

Date started 10/27/2003 19
 Date completed 11/2/2003 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>	<u>1 HR</u>	

Nevada contractor's license number issued by the State Contractor's Board 11752
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
 Signed [Signature] By driller performing actual drilling on-site or contractor
 Date 11/21/03