

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

office use only
Log No. 42283
Permit No. 104
Basin 104
NOTICE OF INTENT No. 594
MW-13C

1. OWNER Bently Pressurized Bearing Co
MAILING ADDRESS 1711 Orbit Way Building 2
Minden NV 89423

ADDRESS AT WELL LOCATION
Douglas County

2. Location NW 1/4 SW 1/4 Sec 8 T 13N R 20E N 39 0.297 W 119 46.010
PERMIT NO. PARCEL NO. 1320-08-002-006 SUBDIVISION NAME

3. WORK PERFORMED			4. PROPOSED USE			5. WELL TYPE		
New Well	Replace	Recondition	Domestic	Irrigation	Test	Cable	Rotary	RVC
Deepen	X Abandon	Other	Municipal/Industrial	X Monitor	Stock	Air	Other	Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Blow down from 145-149				0
Cement from 0-149				0
Installed Tremie to bottom + pumped neat cement to surface				0
We did get returns				0

8. WELL CONSTRUCTION

Depth Drilled	149 feet	Depth Cased	149 feet
HOLE DIAMETER (BIT SIZE)			
	From	To	
inches	0	feet	149 feet
inches		feet	feet
inches		feet	feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4			0	149

Perforations:

Type Perforation	Size perforation	From	To
Mills Knife	1/4 x 3"	feet to	feet
		feet to	feet

Surface Seal X YES No Seal Type:
Depth of Seal 149 feet X Neat Cement
x Pumped Cement Grout
Poured Concrete Grout

Gravel Packed: Yes No
From feet to 149 feet

RECEIVED
04 FEB 19 AM 11:30
STATE ENGINEERS OFFICE

9. WATER LEVEL

Static water level	5 feet below land surface
Artesian flow	0 GPM 0 P.S.I.
Water Temperature	cold Degrees F Quality

Date started 1-15 -04
Date completed 1-20 -04

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	x Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (hours)	

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name McKay Drilling, Inc.
2290 Pioneer Drive
Reno, NV 89509

NV Contractors No. 14170
NV Driller's Lic (on site) 2121

Signed *[Signature]*
By driller performing actual drilling on site or contractor

Date 1-24 -04