

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

office use only  
Log No. 92296  
Permit No. 50651  
Basin 108  
NOTICE OF INTENT N:51589  
MW-15A

1. OWNER Bently Pressurized Bearing Co ADDRESS AT WELL LOCATION  
MAILING ADDRESS 1711 Orbit Way Building 2  
Minden NV 89423

2. Location SW 1/4 NE 1/4 Sec 8 T 13N R 20E N 39 0.478 W 119 45.615 Douglas County  
PERMIT NO. 50651 ? PARCEL NO. 1320-08-002-006 SUBDIVISION NAME

3. WORK PERFORMED			4. PROPOSED USE			5. WELL TYPE		
New Well	Replace	Recondition	Domestic	Irrigation	Test	Cable	Rotary	RVC
Deepen	X Abandon	Other	Municipal/Industrial	X Monitor	Stock	Air	Other	Mud

6. LITHOLOGIC LOG

Material	Water/Strata	From	To	Thickness
Bailed 4' of fill				0
Perfed 12' to 20'				0
Installed Tremie to bottom + pumped neat cement to surface				0
We did get returns				0

8. WELL CONSTRUCTION

Depth Drilled 44 feet Depth Cased 44 feet  
HOLE DIAMETER (BIT SIZE)

	From	To	
inches	0	44	feet
inches			feet
inches			feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6			0	44

Perforations:

Type Perforation	Mills Knife	From	To	feet
Size perforation	1/4 x 3"	12	20	feet
From				feet

Surface Seal X YES No Seal Type:  
Depth of Seal 44 feet X Neat Cement  
x Pumped Cement Grout  
Poured Concrete Grout

Gravel Packed: Yes No  
From feet to 44 feet

9. WATER LEVEL

Static water level 14 feet below land surface  
Artesian flow 0 GPM 0 P.S.I.  
Water Temperature cold Degrees F Quality

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name McKay Drilling, Inc.  
2290 Pioneer Drive  
Reno, NV 89509

NV Contractors No. 14170  
NV Driller's Lic (on site) 2121

Signed *[Signature]*  
By driller performing actual drilling on site or contractor

Date 1-24 -04

Date started 1-15 -04  
Date completed 1-20 -04

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	x Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (hours)	

RECEIVED

04 FEB 19 AM 11:29

STATE ENGINEERS OFFICE