WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92297
Permit No.
Basin 101

NOTICE OF INTENT NO. 54533

1. OWNER Frank Woolsey
MAILING ADDRESS 2161 W. Williams ave.
Fallon, NV 89406

ADDRESS AT WELL LOCATION 4140 Falcon Dr. Fallon,
Nv. 89406

2. LOCATION NW 1/4 SE 1/4 Sec. 21 T 19 N/S R 28 E Churchill County
PERMIT NO. (Issued by Water Resources) | Parcel No. 008-282-60 | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown sand		0	15	15
brown clay		15	22	7
brown sand		22	37	15
gray sand		37	63	26
fine gray sand		63	70	7
brown clay		70	72	2
brown sand	xx	72	75	3

Date started 11/23/2003, 19__
Date completed 11/23/2003, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
14		1hr

8. WELL CONSTRUCTION
Depth Drilled 75 Feet Depth Cased 75 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	75	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	0	20
6 pvc	3.92	.258	20	75

Perforations:
Type perforation saw cut
Size perforation 1/8
From 72 feet to 75 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 75 feet

9. WATER LEVEL
Static water level 14 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name PARSONS DRILLING, INC. (Contractor)
Address P.O. BOX 1265 (Contractor)
FALLON, NV. 89407
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
Signed Wayne Parsons
By driller performing actual drilling on-site or contractor
Date 1/5/2004

USE ADDITIONAL SHEETS IF NECESSARY