WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92298
Permit No.
Basin 137B

NOTICE OF INTENT NO. 32439

1. OWNER USDA, TOIYABE NATIONAL FOREST
MAILING ADDRESS ATTN: L. SPITZLER 1750 FRONT STREET
BOISE, ID 83702

ADDRESS AT WELL LOCATION
BOB SCOTT CAMPGROUND

2. LOCATION NW 1/4 NE 1/4 Sec. 2 T ~~19N~~ N/~~S~~ R 44E E LANDER County
PERMIT NO. 61430 Issued by Water Resources
Parcel No. MA 18N
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN CLAY		0	3	3
LOOSE MC ROCK		3	10	7
BLACK GRANITE\ QUARTZ		10	30	20
See next line		30	45	15
BLACK GRANITE\QUARTZ W YELLOW CLAY				
See next line	X	45	118	73
BLACK GRANITE\QUARTZ\YELLOW STAINS				

Date started 4/15/96 , 19__
Date completed 4/17/96 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [X] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
8		1 hr.

8. WELL CONSTRUCTION
Depth Drilled 116 Feet Depth Cased 116 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 1/4	Inches	0	Feet	50	Feet
6 1/4	Inches	50	Feet	116	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.280	+1	116

Perforations:
Type perforation MACHINE SLOT
Size perforation .090
From 76 feet to 116 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal 50'
Placement Method: [X] Pumped [ ] Poured

Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 12 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Welsco Drilling Corp. Contractor
Address P. O. BOX 888 Contractor
FALLON, NV 89407

Nevada contractor's license number issued by the State Contractor's Board 11752

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996

Signed [signature] By driller performing actual drilling on-site or contractor
Date 4-17-96