WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92393
Permit No.
Basin 101

NOTICE OF INTENT NO. 54538

1. OWNER Jim Ghiglia
MAILING ADDRESS 4353 Santa Fe Dr.
Fallon, NV 89406

ADDRESS AT WELL LOCATION 4330 Santa Fe Dr.
Fallon, Nv. 89406

2. LOCATION NW 1/4 SE 1/4 Sec. 28 T 19 N/S R 28 E Churchill County
PERMIT NO. (Issued by Water Resources) | Parcel No. 008-401-73 | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown sand		0	40	40
brown clay		40	42	2
gray sand		42	50	8
gray silt		50	62	12
brown sand		62	82	20
gray silt		82	125	43
gray sand	xx	125	136	11

Date started 12/19/2003, 19__
Date completed 12/19/2003, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		1hr

8. WELL CONSTRUCTION
Depth Drilled 136 Feet Depth Cased 136 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	136	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	0	20
6pvc	3.92	.258	20	136

Perforations:
Type perforation saw cut
Size perforation 1/8
From 133 feet to 136 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 136 feet

9. WATER LEVEL
Static water level 16'6 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name PARSONS DRILLING, INC. (Contractor)
Address P.O. BOX 1265 (Contractor)
FALLON, NV. 89407
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
Signed Wayne Parsons (By driller performing actual drilling on-site or contractor)
Date 1/5/2004

USE ADDITIONAL SHEETS IF NECESSARY