WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 92306
Permit No.
Basin 101

NOTICE OF INTENT NO. 54540

1. OWNER Jim Ghiglia
MAILING ADDRESS 4353 Santa Fe Dr.
Fallon, NV 89406

ADDRESS AT WELL LOCATION 933 Toas Ct. Fallon, Nv. 89406

2. LOCATION NW 1/4 SE 1/4 Sec. 28 T 19 N/S R 28 E Churchill County
PERMIT NO. _____ Issued by Water Resources
not available Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	30	30
Brown clay		30	33	3
Brown Silt		33	45	12
Gray silt		45	67	22
gray sand		67	74	7
brown sand		74	85	11
brown silt		85	92	7
gray clay		92	100	8
gray sand	xx	100	115	15

Date started 12/17/2003 , 19__
Date completed 12/17/2003 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1hr

8. WELL CONSTRUCTION
Depth Drilled 115 Feet Depth Cased 115 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	115	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	0	20
6 PVC	3.92	.258	20	115

Perforations:
Type perforation saw cut
Size perforation 1/8
From 110 feet to 115 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 115 feet

9. WATER LEVEL
Static water level 14' 3 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name PARSONS DRILLING, INC. Contractor
Address P.O. BOX 1265 Contractor
FALLON, NV. 89407
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
Signed Wayne Parsons
By driller performing actual drilling on-site or contractor
Date 12/29/2003

USE ADDITIONAL SHEETS IF NECESSARY